



DEPARTMENT OF
BUILDING SAFETY

CITY OF OTSEGO
13400 – 90th ST NE / OTSEGO, MN 55330
(763) 441-2593 • (FAX) 441-9163
www.building@ci.otsego.mn.us

CONSTRUCTION AND DEMOLITION

TEMPORARY HEATING EQUIPMENT GUIDELINES & REQUIREMENTS

1403.1 Listed.* Temporary heating devices shall be *listed* and *labeled* in accordance with the *Minnesota Mechanical and Fuel Gas Codes*. Installation, maintenance and use of temporary heating devices shall be in accordance with the terms of the listing.

1403.3 LP-gas heaters.* Fuel supplies, piping, regulators and tanks for LP gas-fired heaters shall comply with the Minnesota Fuel Gas Code.

1403.5 Installation.* Clearance to combustibles from temporary heating devices shall be maintained in accordance with the *labeled* equipment. When in operation, temporary heating devices and tanks shall be fixed in place and protected from damage, dislodgement or overturning in accordance with the manufacturer's instructions. Venting and outdoor air shall be provided during operation.

1403.6 Supervision.* The use of temporary heating devices shall be supervised and maintained only by competent personnel.

All flexible gas lines and LP tanks shall be protected by an approved method:

- 25' max. length without pre-approval from the building official.
- 75' max. length with building official approval.
- Flexible hoses must pass 25-pound, 12-hour test.
- All units must be thermostatically controlled and provided with an approved shut off valve at unit.

Any violation of these requirements could lead to citations, future inspection suspensions or stop work orders.

Address where heater is to be used: _____

Responsible Party Signature

Date

* 2007 MN State Fire Code Section